File Original and First Copy with the Division of Water Management
Second Copy — Owner's Copy
Third Copy — Driller's Copy 32/1E/04/G

WATER WELL REPORT
STATE OF WASHINGTON

Application No. G1-20694
Permit No. 32/01-04G

(1) OWNER: Name [illegible] Address c/o Fakkema & Kingma Inc 4086 400 Ave. Oak Harbor

(2) LOCATION OF WELL: County Island SW ~~SE~~ ¼ NE¼ ½ Sec. 4 T. 32 N., R. 1E W.M.

Bearing and distance from section or subdivision corner 130 FT South & 130 FT West FM NE cor. SW¼, NE¼

(3) PROPOSED USE: Domestic ☒ Industrial ☐ Municipal ☐ Irrigation ☐ Test Well ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one) 2
New well ☒ Method: Dug ☐ Bored ☐
Deepened ☐ Cable ☒ Driven ☐
Reconditioned ☐ Rotary ☐ Jetted ☐

(5) DIMENSIONS: Diameter of well 8 inches.
Drilled ______ ft. Depth of completed well 126 ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 8" Diam. from 0 ft. to 104'2" ft.
Threaded ☐ ______" Diam. from ______ ft. to ______ ft.
Welded ☒ ______" Diam. from ______ ft. to ______ ft.

Perforations: Yes ☐ No ☒
Type of perforator used ______
SIZE of perforations ______ in. by ______ in.
______ perforations from ______ ft. to ______ ft.
______ perforations from ______ ft. to ______ ft.
______ perforations from ______ ft. to ______ ft.

Screens: Yes ☒ No ☐
Manufacturer's Name Cook
Type Stainless Model No. ______
Diam. 8" Slot size #12 from 104 ft. to 110 ft.
Diam. 6" Slot size #8 from 110 ft. to 126 ft.

Gravel packed: Yes ☐ No ☒ Size of gravel: ______
Gravel placed from ______ ft. to ______ ft.

Surface seal: Yes ☐ No ☒ To what depth? ______ ft.
Material used in seal ______
Did any strata contain unusable water? Yes ☐ No ☒
Type of water? ______ Depth of strata ______
Method of sealing strata off ______

(7) PUMP: Manufacturer's Name Reda
Type: Sub H.P. 7½

(8) WATER LEVELS: Land-surface elevation above mean sea level 100-approx
Static level 77 ft. below top of well Date [illegible] 68
Artesian pressure ______ lbs. per square inch Date ______
Artesian water is controlled by ______ (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☒ No ☐ If yes, by whom? Bobs Pumps
Yield: 75 gal./min. with 15 ft. drawdown after 5 hrs.
" " " "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test Sept 68
Bailer test ______ gal./min. with ______ ft. drawdown after ______ hrs.
Artesian flow ______ g.p.m. Date ______
Temperature of water ______ Was a chemical analysis made? Yes ☐ No ☐

(10) WELL LOG:

Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
Gravel	0	2
Grey Sandy Clay	2	11
Hard Pan	11	18
Clay	18	36
Hard Sandy Clay	36	46
Brown dirty Sand	46	86
Water in Sand (dirty)	86	101
Clean Water Sand	101	126
dead Hard Sand	126	

Work started ______, 19___ Completed ______, 19___

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Whidbey Drillers
(Person, firm, or corporation) (Type or print)

Address 1143 W. Ft Nugent Rd.
Oak Harbor Wn.

[Signed] [signature]
(Well Driller)

License No. 223 02 105 15 Date Jan 15, 1973

(USE ADDITIONAL SHEETS IF NECESSARY)

32-1E-4G

Well Tagging Form

Unique Well Tag No: AGA678

RECORD VERIFICATION (check ✓ one)

[✓] Well Report available (please attach this form to the well report and submit it to the Ecology Regional Office near you).
If a well report is not available, please complete a "Water Well Report for an Existing Well" form. This form is available at Ecology's headquarters office. **Do not use this form for wells that do not have a Water Well Report.**

WELL OWNERSHIP, IF DIFFERENT FROM WELL REPORT

First Name: Swantown Water District Last Name:

Street Address: PO Box 610

City: Oak Harbor State: WA 98277

LOCATION OF WELL, IF DIFFERENT FROM WELL REPORT

Well Address: Parcel R13204-262-2721, Swantown Road, Oak Harbor

City: Oak Harbor County: Island

T. 32 N. R. 1 E W.M. Sec. 4 SW ¼ of the NE

Latitude 48 17. 58623 "

Longitude 122 41. 1599 "

Elevation at land surface 120 feet/meters *(circle one)*

SEE BACK SIDE OF PAGE...

RECEIVED
NOV 07 2011
WATER RESOURCES - NWRO

WELL CHARACTERISTICS

Location of Well identification Tag: Strapped to the discharge pipe next to the well casing in well enclosure next to parking lot this is the 8" well.

D	C	B	A
E	F	G	H
M	L	K	J
N	P	Q	R

well

Scale 1:24,000 (1" = 2,000')

Indicate the location of the well within the Section by drawing a dot at that point

SECTION 4

COMMENTS:

This is well #1, source SO2. It is south of the club house for Whidbey Golf & Country Club